



Government Of West Bengal
Office Of The Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo no.:IND/WB/FES/20182019/22440

Date: 26-09-2020

From:
Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services

To: Sachis Kiran Roy Memorial Trust Adamas World School Adamas Knowledge City
Dag No. S 353 381, Mouza: Sadarpur, J.L. No. 32 under Ichapur Nilganj Gram Panchayet, Barrackpore - Barasat
Road, Berberia, P.S. - Barasat, Post - Jagannathpur, Dist -North 24 Parganas

Sub: Renewal of Fire Safety Certificate for the occupancy of G+III storied under group Educational Building in the name of "Adamas World School" at Premises – Adamas World School, Adamas Knowledge City, Dag No- S 353, 381, Mouza- Sadarpur, under Ichhapur Nilganj Gram Pnachayet, PS- Barasat, 24 Pgs(N).

This is in reference to your application no. 0125191201100956 dated 01-07-2020 regarding the Renewal of Fire Safety Certificate for the occupancy of G+III storied under group Educational Building in the name of "Adamas World School" at Premises – Adamas World School, Adamas Knowledge City, Dag No- S 353, 381, Mouza- Sadarpur, under Ichhapur Nilganj Gram Pnachayet, PS- Barasat, 24 Pgs(N).

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. Parking will not be allowed on the Driveway.
2. The Interior finish decoration of buildings shall be made with low flame spread material confirming I.S. Specification.
3. To eliminate risk of Fire Hazards, good Housekeeping both for inside and outside of the building shall be strictly maintained.

- 4.Existing electrical wiring of the whole buildings shall have to be carefully checked for any wear & tear in them, particularly lines above false ceiling and ducts. If required the old electrical lines shall have to be replaced with new electrical lines. Cables shall always be laid in MS conduit pipes continuously bonded to the earth.
- 5.Annual Electrical Audit by competent authority will have to be conducted and proper documentation will also have to be maintained regarding the same.
- 6.A Fire Control Room including CCTV system shall have to be maintained which will observe all the floors of the building.
- 7.The Notice of Fire Fighting, Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the building.
8. The Employees & Security Staff shall be conversant with the installed Fire Fighting Equipment of the building and to operate in the event of Fire & Testing.
- 9.Mock Fire Practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
- 10.A crew of trained fireman shall be maintained round the clock for safety of the building.
- 11.First Aid Fire Fighting system shall be provided as per I.S. specification in floor level of the building.
- 12.Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
- 13.Periodical flashing of water from water based suppression system (Hydrant System) shall be made to maintain the efficient working performance of above mentioned system.
- 14.The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
- 15.Vertical Electrical Shaft will have to be sealed at each floor level of the building by fire resisting materials to prevent penetration of fire & smoke within 30 days from the date of issuance of this certificate.
- 16.This Renewal of Fire Safety Certificate is valid for Three (3) Years and has to be renewed within validity limit from the date of issuance of this letter.
- 17.This certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding performance of all the Life & Fire Safety arrangements and installations of the building.

Divisional Fire Officer,North 24 Parganas
West Bengal Fire & Emergency Services